


DATABLAD MODULEX 250A

VARENR. 70262 MÅLERMODUL EBM 250A M/OVERSPENNINGSVERN

Prod.nr.	Innhold	Ant.
4383604	Effektbryter 4P T4N 250 -LS/I In=160	1
75144	Overspenningsvern OVR T2 3L 40400 PX	1
75145	Sikringsholder	1
72961	Målertrafo KS60-300-K KL 0,2s	3
1SDA064550R1	Kabelklemme FC CuAl T4 1x240mm ²	4
4383656	Faseskiller PB100 T4-T5 4p lav	4
75146	Glassikring 10A for overspenningsvern	3
1SCA022512R5360	Pluggkontakt 125/160A	2



Effektbryter 4P T4N 250 -LS/I In=160

Elnummer: 4383604
Fabrikat: ABB SACE

[FDV](#)



Kabelklemme FC CuAl T4 1x240mm²

Elnummer: 1SDA064550R1
Tiltrekningskraft: 16Nm



Overspenningsvern OVR T2 3L 40400 PX

Elnummer: 1623898
Fabrikat: ABB



Faseskiller PB100 T4-T5 4p lav

Elnummer: 4383656
Fabrikat: ABB Sace

[FDV](#)



Sikringsholder

Elnummer: 1425442
Fabrikat: ABB

[FDV](#)



Glassikring 10A for overspenningsvern

Elnummer: 1655016
Fabrikat: ABB

[FDV](#)



Målertrafo KS60-300-K KL 0,2s

Elnummer: E4278080
Fabrikat: Hugo Tilquist AB



Pluggkontakt 125/160A

Elnummer: 1SCA022512R5360
PG400S4

DATABLAD MODULEX 250A
VAREN. 70262 MÅLERMODUL EBM 250A M/OVERSPENNINGSVERN

Enlinjeskjema

